

Issaquah School District No. 411

Resolution No.1181

A RESOLUTION of the Board of Directors of the Issaquah School District No. 411, King County, Issaquah, Washington to adopt a plan for remedial action to reduce lead contamination in drinking water; and

WHEREAS, the Issaquah School District prioritizes the health, safety and welfare of our students and staff;

WHEREAS, RCW 28A.210.410, regarding lead contamination at drinking water outlets in school districts with buildings built, or with all plumbing replaced, before 2016, went into effect in July 2021; and

WHEREAS, RCW 28A.210.410 mandates that a school board that receives lead test results revealing an elevated lead level at one or more drinking water outlets adopt a school district action plan for remediation; and

WHEREAS, the action plan must describe mitigation measures implemented since the lead test result was received and post-remediation re-testing; and

WHEREAS, RCW 28A.210.40 specifies that the schedule of remediation activities “may be based on the availability of state or federal funding for remediation activities”; and

WHEREAS, the action plan may include sampling and testing of the drinking water entering the school when the results of testing for lead contamination at drinking water outlets within the school district indicate that the infrastructure of the public water system is a documented significant contributor to the elevated lead levels; and

NOW THEREFORE, BE IT RESOLVED, that the Issaquah School Board of Directors hereby adopts the action plan in Attachment A.

BE IT FURTHER RESOLVED, that execution of this Resolution is conclusive evidence of the Board's approval of this action and of the authority granted herein. The School Board warrants that it has, and at the time of this action had, full power and lawful authority to adopt this instrument.

Adopted and approved this 24th day of March, 2022.

President

Director

Director

Director

Director

Ron Thiele, Secretary

See Attachment A

Attachment A: Drinking Fountains and Sinks with needed remediation under new 5PPB Standard

| School | Fixture type and room type | Room Description | Type of Space | Fixture Type | Location | room # | Result (ppb) | Actions | Schedule |
|--------------|----------------------------|-------------------------|---------------------|--------------|--|-----------|--------------|------------------------|-----------|
| Apollo | Sink classroom - regular | classroom | classroom - regular | Sink | Room 104 Classroom - sink by door | 104 | 12 | Install filter, retest | 3/31/2023 |
| Apollo | Sink classroom - regular | classroom | classroom - regular | Sink | Room 104 Classroom - sink by window | 104 | 5.1 | Install filter, retest | 3/31/2023 |
| Apollo | Sink classroom - regular | kindergarten classroom | classroom - regular | Sink | Room 102 Classroom - sink by doors/windows | 102 | 12 | Install filter, retest | 3/31/2023 |
| Apollo | Sink classroom - regular | kindergarten classroom | classroom - regular | Sink | Room 101 Classroom - sink by doors/windows | 101 | 5.2 | Install filter, retest | 3/31/2023 |
| Apollo | Sink work room | faculty workroom | work room | Sink | Room 118 Faculty - sink | 118 | 11 | Install filter, retest | 3/31/2023 |
| Apollo | Sink classroom - regular | LRC2 classroom | classroom - regular | Sink | Room 203 Classroom - right sink | 203 | 6.4 | Install filter, retest | 3/31/2023 |
| Apollo | Sink classroom - regular | LRC1 classroom | classroom - regular | Sink | Room 201 Classroom - sink | 201 | 8.6 | Install filter, retest | 3/31/2023 |
| Apollo | Sink office | speech therapist office | office | Sink | Room 217 Office - sink | 217 | 11 | Install filter, retest | 3/31/2023 |
| Apollo | Sink | | | Sink | Storage Room - sink | unknown | 10 | Install filter, retest | 3/31/2023 |
| Apollo | Sink | | | Sink | | 2 unknown | 14 | Install filter, retest | 3/31/2023 |
| Apollo | Sink classroom - regular | classroom | classroom - regular | Sink | Room 401 Classroom - sink | 401 | 12 | Install filter, retest | 3/31/2023 |
| Apollo | Sink classroom - regular | classroom | classroom - regular | Sink | Room 402 Classroom - sink | 402 | 9.1 | Install filter, retest | 3/31/2023 |
| Apollo | Sink classroom - regular | classroom | classroom - regular | Sink | Room 403 Classroom - sink | 403 | 5.8 | Install filter, retest | 3/31/2023 |
| Apollo | Sink classroom - regular | classroom | classroom - regular | Sink | Room 406 Classroom - sink | 406 | 11 | Install filter, retest | 3/31/2023 |
| Apollo | Sink classroom - regular | classroom | classroom - regular | Sink | Room 405 Classroom - sink | 405 | 5.1 | Install filter, retest | 3/31/2023 |
| Apollo | Sink classroom - regular | classroom | classroom - regular | Sink | Room 404 Classroom - sink | 404 | 5.8 | Install filter, retest | 3/31/2023 |
| Briarwood | Sink classroom - regular | classroom | classroom - regular | Sink | Room 254, Reading Room - sink | 254 | 6.5 | Install filter, retest | 3/31/2023 |
| Beaver Lake | Sink kitchen | kitchen | kitchen | Sink | Kitchen, South Wall, Far Left Sink | 118 | 6.3 | Install filter, retest | 3/31/2023 |
| Beaver Lake | Sink kitchen | kitchen | kitchen | Sink | Kitchen, Right Dishwashing Sink | 118 | 5.2 | Install filter, retest | 3/31/2023 |
| Beaver Lake | Sink commons | staff lounge | commons | Sink | Staff Lounge | 108 | 17 | Install filter, retest | 3/31/2023 |
| Beaver Lake | Sink classroom - regular | classroom | classroom - regular | Sink | Room B-6 | B6 | 12 | Install filter, retest | 3/31/2023 |
| Beaver Lake | Sink classroom - regular | classroom | classroom - regular | Sink | Room B-4 | B4 | 19 | Install filter, retest | 3/31/2023 |
| Beaver Lake | Sink classroom - regular | classroom | classroom - regular | Sink | Room B-5 | B5 | 17 | Install filter, retest | 3/31/2023 |
| Beaver Lake | Sink classroom - regular | classroom | classroom - regular | Sink | Room B-2 | B2 | 17 | Install filter, retest | 3/31/2023 |
| Beaver Lake | Sink classroom - regular | classroom | classroom - regular | Sink | Room B-1, Left Sink | B4 | 19 | Install filter, retest | 3/31/2023 |
| Beaver Lake | Sink classroom - regular | classroom | classroom - regular | Sink | Room B-1, Right Sink | B1 | 13 | Install filter, retest | 3/31/2023 |
| Beaver Lake | Sink classroom - regular | classroom | classroom - regular | Sink | Room A-5, South Wall, Left Sink | A5 | 8.8 | Install filter, retest | 3/31/2023 |
| Beaver Lake | Sink classroom - regular | classroom | classroom - regular | Sink | Room D-7, West Wall Sink | D7 | 13 | Install filter, retest | 3/31/2023 |
| Beaver Lake | Sink classroom - regular | classroom | classroom - regular | Sink | Room D-6 | D6 | 13 | Install filter, retest | 3/31/2023 |
| Beaver Lake | Sink classroom - regular | classroom | classroom - regular | Sink | Room D-3 | D3 | 14 | Install filter, retest | 3/31/2023 |
| Beaver Lake | Sink classroom - regular | classroom | classroom - regular | Sink | Room D-1 | D1 | 10 | Install filter, retest | 3/31/2023 |
| Beaver Lake | Sink classroom - regular | classroom | classroom - regular | Sink | Room D-2 | D2 | 18 | Install filter, retest | 3/31/2023 |
| Beaver Lake | Sink classroom - regular | classroom | classroom - regular | Sink | Room C-11 | C11 | 18 | Install filter, retest | 3/31/2023 |
| Beaver Lake | Sink classroom - regular | classroom | classroom - regular | Sink | Room C-6 | C6 | 15 | Install filter, retest | 3/31/2023 |
| Beaver Lake | Sink classroom - regular | classroom | classroom - regular | Sink | Room C-4 | C4 | 18 | Install filter, retest | 3/31/2023 |
| Beaver Lake | Sink classroom - regular | classroom | classroom - regular | Sink | Room C-3 | C3 | 16 | Install filter, retest | 3/31/2023 |
| Beaver Lake | Sink classroom - regular | classroom | classroom - regular | Sink | Room C-2 | C2 | 19 | Install filter, retest | 3/31/2023 |
| Challenger | Sink classroom - regular | classroom | classroom - regular | Sink | Room 213 Classroom - sink | 213 | 9.7 | Install filter, retest | 3/31/2023 |
| Challenger | Sink classroom - regular | classroom | classroom - regular | Sink | Room 208 Classroom - sink | 208 | 6.3 | Install filter, retest | 3/31/2023 |
| Challenger | Sink classroom - regular | classroom | classroom - regular | Sink | Room 211 Classroom - sink | 211 | 5.3 | Install filter, retest | 3/31/2023 |
| Challenger | Sink classroom - regular | classroom | classroom - regular | Sink | Room 206 Classroom - sink | 206 | 9.1 | Install filter, retest | 3/31/2023 |
| Challenger | Sink classroom - regular | classroom | classroom - regular | Sink | Room 413 Classroom - sink | 413 | 7.4 | Install filter, retest | 3/31/2023 |
| Challenger | Sink classroom - regular | classroom | classroom - regular | Sink | Room 409 Classroom - sink | 409 | 9.1 | Install filter, retest | 3/31/2023 |
| Challenger | Sink classroom - regular | classroom | classroom - regular | Sink | Room 405 Classroom - sink | 405 | 6.5 | Install filter, retest | 3/31/2023 |
| Challenger | Sink classroom - regular | classroom | classroom - regular | Sink | Room 403 Classroom - sink | 403 | 9.5 | Install filter, retest | 3/31/2023 |
| Challenger | Sink classroom - regular | classroom | classroom - regular | Sink | Room 404 Classroom - sink | 404 | 8.4 | Install filter, retest | 3/31/2023 |
| Challenger | Sink classroom - regular | classroom | classroom - regular | Sink | Room 308 Classroom - sink | 308 | 5.2 | Install filter, retest | 3/31/2023 |
| Challenger | Sink classroom - regular | classroom | classroom - regular | Sink | Room 306 Classroom - sink | 306 | 11 | Install filter, retest | 3/31/2023 |
| Challenger | Sink classroom - regular | classroom | classroom - regular | Sink | Room 305 Classroom - sink | 305 | 5.3 | Install filter, retest | 3/31/2023 |
| Challenger | Sink classroom - regular | classroom | classroom - regular | Sink | Room 304 Classroom - sink | 304 | 5.8 | Install filter, retest | 3/31/2023 |
| Challenger | Sink classroom - regular | classroom | classroom - regular | Sink | Room 303 Classroom - sink | 303 | 14 | Install filter, retest | 3/31/2023 |
| Challenger | Sink classroom - regular | classroom | classroom - regular | Sink | Room 302 Classroom - sink | 302 | 6.1 | Install filter, retest | 3/31/2023 |
| Cougar Ridge | Sink classroom - regular | classroom | classroom - regular | Sink | Room 138, Classroom - sink | 138 | 11 | Install filter, retest | 3/31/2023 |

Attachment A: Drinking Fountains and Sinks with needed remediation under new 5PPB Standard

| | | | | | | | | | |
|---------------|--------------------------|------------------------|---------------------|------|--|-----|-----|------------------------|-----------|
| Cougar Ridge | Sink classroom - regular | kindergarten classroom | classroom - regular | Sink | Room 140, Classroom - left sink, sink | 140 | 12 | Install filter, retest | 3/31/2023 |
| Cougar Ridge | Sink classroom - regular | kindergarten classroom | classroom - regular | Sink | Room 140, Classroom - right sink, sink | 140 | 12 | Install filter, retest | 3/31/2023 |
| Cougar Ridge | Sink classroom - regular | kindergarten classroom | classroom - regular | Sink | Room 142 Classroom - left sink, initial draw | 142 | 10 | Install filter, retest | 3/31/2023 |
| Cougar Ridge | Sink classroom - regular | kindergarten classroom | classroom - regular | Sink | Room 142, Classroom - right sink, sink | 142 | 11 | Install filter, retest | 3/31/2023 |
| Cougar Ridge | Sink classroom - regular | classroom | classroom - regular | Sink | Room 144, Classroom - sink | 144 | 11 | Install filter, retest | 3/31/2023 |
| Cougar Ridge | Sink classroom - regular | classroom | classroom - regular | Sink | Room 146, Classroom - sink | 146 | 9.3 | Install filter, retest | 3/31/2023 |
| Cougar Ridge | Sink classroom - regular | classroom | classroom - regular | Sink | Room 148 Classroom - sink, initial draw | 148 | 12 | Install filter, retest | 3/31/2023 |
| Cougar Ridge | Sink commons | staff lounge | commons | Sink | Room 167, Staff Room - left sink | 110 | 16 | Install filter, retest | 3/31/2023 |
| Cougar Ridge | Sink classroom - regular | classroom | classroom - regular | Sink | Room 168, Classroom - sink | 168 | 7.4 | Install filter, retest | 3/31/2023 |
| Cougar Ridge | Sink classroom - regular | classroom | classroom - regular | Sink | Room 172, Classroom - sink | 172 | 9 | Install filter, retest | 3/31/2023 |
| Cougar Ridge | Sink classroom - regular | classroom | classroom - regular | Sink | Room 174, Classroom - sink | 174 | 16 | Install filter, retest | 3/31/2023 |
| Cougar Ridge | Sink classroom - regular | classroom | classroom - regular | Sink | Room 176, Classroom - sink | 176 | 15 | Install filter, retest | 3/31/2023 |
| Cougar Ridge | Sink classroom - regular | classroom | classroom - regular | Sink | Room 178, Classroom - sink | 178 | 5.3 | Install filter, retest | 3/31/2023 |
| Cougar Ridge | Sink classroom - regular | classroom | classroom - regular | Sink | Room 180, Classroom - sink | 180 | 8 | Install filter, retest | 3/31/2023 |
| Cougar Ridge | Sink classroom - regular | classroom | classroom - regular | Sink | Room 182, Classroom - sink | 182 | 7.3 | Install filter, retest | 3/31/2023 |
| Cougar Ridge | Sink classroom - regular | classroom | classroom - regular | Sink | Room 184, Classroom - sink | 184 | 5.9 | Install filter, retest | 3/31/2023 |
| Cascade Ridge | Sink hallway | hallway | hallway | Sink | First floor NW wing common area - sink | 140 | 5.8 | Install filter, retest | 3/31/2023 |
| Cascade Ridge | Sink classroom - regular | classroom | classroom - regular | Sink | Room 142 Classroom - sink | 142 | 6.5 | Install filter, retest | 3/31/2023 |
| Cascade Ridge | Sink classroom - regular | classroom | classroom - regular | Sink | Room 141 Classroom - sink | 141 | 13 | Install filter, retest | 3/31/2023 |
| Cascade Ridge | Sink classroom - regular | classroom | classroom - regular | Sink | Room 145 Classroom - sink | 145 | 7.3 | Install filter, retest | 3/31/2023 |
| Cascade Ridge | Sink classroom - regular | classroom | classroom - regular | Sink | Room 163 Classroom - sink | 163 | 8.7 | Install filter, retest | 3/31/2023 |
| Cascade Ridge | Sink classroom - regular | classroom | classroom - regular | Sink | Room 162 Classroom - sink | 162 | 7.3 | Install filter, retest | 3/31/2023 |
| Cascade Ridge | Sink classroom - regular | classroom | classroom - regular | Sink | Room 161 Classroom - sink | 161 | 8.7 | Install filter, retest | 3/31/2023 |
| Cascade Ridge | Sink hallway | hallway | hallway | Sink | Second floor NW wing common area - sink | 240 | 7.2 | Install filter, retest | 3/31/2023 |
| Cascade Ridge | Sink classroom - regular | classroom | classroom - regular | Sink | Room 245 Classroom - sink | 245 | 12 | Install filter, retest | 3/31/2023 |
| Cascade Ridge | Sink hallway | hallway | hallway | Sink | Second floor NE wing common area - sink | 260 | 5.2 | Install filter, retest | 3/31/2023 |
| Cascade Ridge | Sink classroom - regular | classroom | classroom - regular | Sink | Room 264 Classroom - sink | 264 | 5.1 | Install filter, retest | 3/31/2023 |
| Cascade Ridge | Sink classroom - regular | classroom | classroom - regular | Sink | Room 266 Classroom - sink | 266 | 13 | Install filter, retest | 3/31/2023 |
| Cascade Ridge | Sink classroom - regular | classroom | classroom - regular | Sink | Room 262 Classroom - sink | 262 | 15 | Install filter, retest | 3/31/2023 |
| Cascade Ridge | Sink classroom - regular | classroom | classroom - regular | Sink | Room 212 Special Education bathroom - sink | 212 | 5.6 | Install filter, retest | 3/31/2023 |
| Creekside | Sink hallway | hallway | hallway | Sink | Second Floor Northwest Wing Common Area - sink | 240 | 11 | Install filter, retest | 3/31/2023 |
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 244 Classroom - sink | 244 | 6.2 | Install filter, retest | 3/31/2023 |
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 245 Classroom - sink | 245 | 6.3 | Install filter, retest | 3/31/2023 |
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 246 Classroom - sink | 246 | 5.6 | Install filter, retest | 3/31/2023 |
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 242 Classroom - sink | 242 | 12 | Install filter, retest | 3/31/2023 |
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 241 Classroom - sink | 241 | 8.2 | Install filter, retest | 3/31/2023 |
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 247 Classroom - sink | 247 | 5.4 | Install filter, retest | 3/31/2023 |
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 254 Classroom - sink | 254 | 9.3 | Install filter, retest | 3/31/2023 |
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 264 Classroom - sink | 264 | 7.4 | Install filter, retest | 3/31/2023 |
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 265 Classroom - sink | 265 | 8.3 | Install filter, retest | 3/31/2023 |
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 263 Classroom - sink | 263 | 6.1 | Install filter, retest | 3/31/2023 |
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 266 Classroom - sink | 266 | 8.1 | Install filter, retest | 3/31/2023 |
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 262 Classroom - sink | 262 | 7 | Install filter, retest | 3/31/2023 |
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 267 Classroom - sink | 267 | 12 | Install filter, retest | 3/31/2023 |
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 261 Classroom - sink | 261 | 5.8 | Install filter, retest | 3/31/2023 |
| Creekside | Sink hallway | hallway | hallway | Sink | First Floor Northwest Wing Common Area - sink | 140 | 11 | Install filter, retest | 3/31/2023 |
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 146 Classroom - sink | 146 | 6.2 | Install filter, retest | 3/31/2023 |
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 142 Classroom - sink | 142 | 8 | Install filter, retest | 3/31/2023 |
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 147 Classroom - sink | 147 | 7.9 | Install filter, retest | 3/31/2023 |
| Creekside | Sink hallway | hallway | hallway | Sink | First Floor Southwest Wing Common Area - sink | 160 | 7.9 | Install filter, retest | 3/31/2023 |
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 164 Classroom - sink | 164 | 11 | Install filter, retest | 3/31/2023 |
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 163 Classroom - sink | 163 | 5.9 | Install filter, retest | 3/31/2023 |
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 166 Classroom - sink | 166 | 6.3 | Install filter, retest | 3/31/2023 |
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 162 Classroom - sink | 162 | 16 | Install filter, retest | 3/31/2023 |

Attachment A: Drinking Fountains and Sinks with needed remediation under new 5PPB Standard

| | | | | | | | | | |
|-----------|--------------------------|-------------|---------------------|------|--|------|------|------------------------|-----------|
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 167 Classroom - sink | 167 | 12 | Install filter, retest | 3/31/2023 |
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 161 Classroom - sink | 161 | 7.4 | Install filter, retest | 3/31/2023 |
| Creekside | Sink classroom - regular | classroom | classroom - regular | Sink | Room 112 Classroom - sink | 112 | 8.4 | Install filter, retest | 3/31/2023 |
| Creekside | Sink kitchen | kitchen | kitchen | Sink | Kitchen - north sink | 175 | 17 | Install filter, retest | 3/31/2023 |
| Creekside | Sink kitchen | kitchen | kitchen | Sink | Kitchen - east sink | 175 | 7.2 | Install filter, retest | 3/31/2023 |
| Creekside | Sink kitchen | kitchen | kitchen | Sink | Kitchen - left dishwashing sink | 175 | 11 | Install filter, retest | 3/31/2023 |
| Creekside | Sink kitchen | kitchen | kitchen | Sink | Kitchen - right dishwashing sink | 175 | 14 | Install filter, retest | 3/31/2023 |
| Discovery | Sink kitchen | kitchen | kitchen | Sink | Kitchen - sink across from kettle | 200C | 6.51 | Install filter, retest | 3/31/2023 |
| Discovery | Sink kitchen | kitchen | kitchen | Sink | Kitchen - handwashing sink | 200C | 5.34 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 13 - sink | 190 | 13 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 14 - sink | 188 | 15 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 15 - sink | 186 | 12.4 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 16 - sink | 184 | 14.4 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 17 - sink | 182 | 14.1 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 18 - sink | 180 | 10 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 18 - sink | 180 | 17.5 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 19 - sink | 178 | 19.6 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 20 - sink | 176 | 11 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 20 - sink | 176 | 19.4 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 21 - sink | 174 | 11.7 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 22 - sink | 172 | 6.1 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 22 - sink | 172 | 19.6 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 23 - sink | 170 | 9 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 23 - sink | 170 | 17.4 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 24 - sink | 168 | 8.1 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 24 - sink | 168 | 19.2 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 3 - sink | 126 | 16 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 4 - sink | 128 | 15 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 4 - sink | 128 | 19.9 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 5 - sink | 130 | 14 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 5 - sink | 130 | 19.4 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 6 - sink | 132 | 12 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 7 - left sink | 134 | 11.8 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 7 - right sink | 134 | 15 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 7 - right sink | 134 | 19.7 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 8 - right sink | 136 | 16 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 9 - sink | 138 | 12 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 9 - sink | 138 | 18.3 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 10 - sink | 140 | 8.8 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 10 - sink | 140 | 15.3 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 11 - sink | 160 | 9.6 | Install filter, retest | 3/31/2023 |
| Discovery | Sink classroom - regular | classroom | classroom - regular | Sink | Room 11 - sink | 160 | 15 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink kitchen | kitchen | kitchen | Sink | Kitchen, Dishwash Bay on Common Room Wall - right sink | 403 | 8.5 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink kitchen | kitchen | kitchen | Sink | Kitchen, in Back Hallway - utility sink | 403 | 5.5 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink health | health room | health | Sink | Room 311, Health Room - sink | 311 | 8.1 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink classroom - regular | classroom | classroom - regular | Sink | Room 505, Classroom - sink | 505 | 11 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink classroom - regular | classroom | classroom - regular | Sink | Room 504, Classroom - sink | 504 | 6 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink classroom - regular | classroom | classroom - regular | Sink | Room 503, Classroom - sink | 503 | 17 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink classroom - regular | classroom | classroom - regular | Sink | Room 502, Classroom - sink | 502 | 16 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink classroom - regular | classroom | classroom - regular | Sink | Room 501, Classroom - sink | 501 | 19 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink classroom - regular | classroom | classroom - regular | Sink | Room 506, Classroom - left sink fixture, sink | 506 | 10 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink classroom - regular | classroom | classroom - regular | Sink | Room 506, Classroom - right sink fixture, sink | 506 | 14 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink classroom - regular | classroom | classroom - regular | Sink | Room 507, Classroom - left sink fixture, sink | 507 | 20 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink classroom - regular | classroom | classroom - regular | Sink | Room 507, Classroom - right sink fixture, sink | 507 | 12 | Install filter, retest | 3/31/2023 |

Attachment A: Drinking Fountains and Sinks with needed remediation under new 5PPB Standard

| | | | | | | | | | |
|-----------------|--------------------------|-------------|---------------------|------|--|-------|------|------------------------|-----------|
| Endeavour | Sink classroom - regular | classroom | classroom - regular | Sink | Room 508, Classroom - sink | 508 | 18 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink classroom - regular | classroom | classroom - regular | Sink | Room 509, Classroom - sink | 509 | 13 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink classroom - regular | classroom | classroom - regular | Sink | Room 510, Classroom - sink | 510 | 17 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink classroom - regular | classroom | classroom - regular | Sink | Room 112, Classroom - sink | 112 | 8.2 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink classroom - regular | classroom | classroom - regular | Sink | Room 111, Classroom - sink | 111 | 6.9 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink classroom - regular | classroom | classroom - regular | Sink | Room 110, Bathroom - sink | 110 | 12 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink classroom - regular | classroom | classroom - regular | Sink | Room 109, Classroom - sink | 109 | 13 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink classroom - regular | classroom | classroom - regular | Sink | Room 108, Bathroom - sink | 108 | 16 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink classroom - regular | classroom | classroom - regular | Sink | Room 107, Classroom - sink | 107 | 15 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink classroom - regular | classroom | classroom - regular | Sink | Room 106, Classroom - sink | 106 | 15 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink classroom - regular | classroom | classroom - regular | Sink | Room 105, Classroom - sink | 105 | 12 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink classroom - regular | classroom | classroom - regular | Sink | Room 104, Classroom - sink | 104 | 15 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink classroom - regular | classroom | classroom - regular | Sink | Room 103, Classroom - sink | 103 | 11 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink classroom - regular | classroom | classroom - regular | Sink | Room 102, Classroom - sink | 102 | 16 | Install filter, retest | 3/31/2023 |
| Endeavour | Sink kitchen | kitchen | kitchen | Sink | Kitchen, Middle Island-Metal Sink | 403 | 8.84 | Install filter, retest | 3/31/2023 |
| Gibson Ek | Sink classroom - regular | classroom | classroom - regular | Sink | Room 201, Classroom - sink | 201 | 5.9 | Install filter, retest | 3/31/2023 |
| Issaquah High | Sink kitchen | concessions | kitchen | Sink | Room 1612, Concessions - left sink | 1612 | 5.8 | Install filter, retest | 3/31/2023 |
| Issaquah High | Sink kitchen | concessions | kitchen | Sink | Room 1612, Concessions - center sink | 1612 | 6 | Install filter, retest | 3/31/2023 |
| Issaquah High | Sink kitchen | Kitchen | kitchen | Sink | Room 1502, Kitchen - S dishwasher station - sink | 1502 | 12 | Install filter, retest | 3/31/2023 |
| Issaquah High | Sink kitchen | Kitchen | kitchen | Sink | Room 1502, Kitchen - N dishwasher bay - right sink | 1502 | 7.6 | Install filter, retest | 3/31/2023 |
| Issaquah High | Sink kitchen | snack bar | kitchen | Sink | Room 1501B, Spirit - SE sink | 1501B | 7.7 | Install filter, retest | 3/31/2023 |
| Issaquah High | Sink classroom - regular | classroom | classroom - regular | Sink | Room 2311 - sink | 2311 | 5.2 | Install filter, retest | 3/31/2023 |
| Issaquah High | Sink classroom - regular | classroom | classroom - regular | Sink | Room 3311 - sink | 3311 | 6.9 | Install filter, retest | 3/31/2023 |
| Issaquah High | Sink classroom - regular | classroom | classroom - regular | Sink | Room 3306 - sink | 3306 | 14 | Install filter, retest | 3/31/2023 |
| Issaquah Valley | Sink kitchen | kitchen | kitchen | Sink | Kitchen - dishwashing sink | 612 | 5.6 | Install filter, retest | 3/31/2023 |
| Issaquah Valley | Sink kitchen | kitchen | kitchen | Sink | Kitchen - dishwashing sink | 612 | 6.1 | Install filter, retest | 3/31/2023 |
| Issaquah Valley | Sink classroom - regular | classroom | classroom - regular | Sink | Room 306 - sink | 306 | 10 | Install filter, retest | 3/31/2023 |
| Issaquah Valley | Sink classroom - regular | classroom | classroom - regular | Sink | Room 304 - sink | 304 | 7 | Install filter, retest | 3/31/2023 |
| Issaquah Valley | Sink classroom - regular | classroom | classroom - regular | Sink | Room 401 - sink | 401 | 7.5 | Install filter, retest | 3/31/2023 |
| Issaquah Valley | Sink classroom - regular | classroom | classroom - regular | Sink | Room 105 - sink | 105 | 5.3 | Install filter, retest | 3/31/2023 |
| Issaquah Valley | Sink classroom - regular | classroom | classroom - regular | Sink | Room 316 - sink | 316 | 5.3 | Install filter, retest | 3/31/2023 |
| Issaquah Valley | Sink classroom - regular | classroom | classroom - regular | Sink | Room 301 - sink | 301 | 5.9 | Install filter, retest | 3/31/2023 |
| Liberty High | Sink kitchen | kitchen | kitchen | Sink | Kitchen, South Island, Sink on End | 3203 | 7.2 | Install filter, retest | 3/31/2023 |
| Liberty High | Sink kitchen | kitchen | kitchen | Sink | Kitchen, North Kettle | 3203 | 5.1 | Install filter, retest | 3/31/2023 |
| Liberty High | Sink kitchen | kitchen | kitchen | Sink | Kitchen, North Island, Sink on End | 3203 | 10 | Install filter, retest | 3/31/2023 |
| Liberty High | Sink kitchen | concessions | kitchen | Sink | Concessions, Hand wash station | 2110 | 19 | Install filter, retest | 3/31/2023 |
| Liberty High | Sink kitchen | concessions | kitchen | Sink | Concessions, Left sink | 2110 | 12 | Install filter, retest | 3/31/2023 |
| Liberty High | Sink kitchen | concessions | kitchen | Sink | Concessions, Left center sink | 2110 | 13 | Install filter, retest | 3/31/2023 |
| Liberty High | Sink kitchen | concessions | kitchen | Sink | Concessions, Right center sink | 2110 | 9.3 | Install filter, retest | 3/31/2023 |
| Liberty High | Sink kitchen | concessions | kitchen | Sink | Concessions, Left sink | 2110 | 18 | Install filter, retest | 3/31/2023 |
| Liberty High | Sink kitchen | concessions | kitchen | Sink | Concessions, Right center sink | 2110 | 8.1 | Install filter, retest | 3/31/2023 |
| Maple Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 405 | 405 | 14 | Install filter, retest | 3/31/2023 |
| Maple Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 403 | 403 | 8.8 | Install filter, retest | 3/31/2023 |
| Maple Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 402 | 402 | 5.9 | Install filter, retest | 3/31/2023 |
| Maple Hills | Sink hallway | hallway | hallway | Sink | 400 Wing, Shared Area, Right Sink | 400A | 9.9 | Install filter, retest | 3/31/2023 |
| Maple Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 306 | 306 | 17 | Install filter, retest | 3/31/2023 |
| Maple Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 305 | 305 | 14 | Install filter, retest | 3/31/2023 |
| Maple Hills | Sink | | | Sink | 300 Wing, Shared Area, Left Sink | 300B | 14 | Install filter, retest | 3/31/2023 |
| Maple Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 303 | 303 | 8.6 | Install filter, retest | 3/31/2023 |
| Maple Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 302 | 302 | 13 | Install filter, retest | 3/31/2023 |
| Maple Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 301 | 301 | 18 | Install filter, retest | 3/31/2023 |
| Maple Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 206 | 206 | 8.5 | Install filter, retest | 3/31/2023 |
| Maple Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 205 | 205 | 8.3 | Install filter, retest | 3/31/2023 |
| Maple Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 204 | 204 | 14 | Install filter, retest | 3/31/2023 |

Attachment A: Drinking Fountains and Sinks with needed remediation under new 5PPB Standard

| | | | | | | | | | |
|-----------------|--------------------------|-----------------|---------------------|------|--|---------|------|------------------------|-----------|
| Maple Hills | Sink hallway | hallway | hallway | Sink | 200 Wing, Shared Area, Right Sink | 200A | 14 | Install filter, retest | 3/31/2023 |
| Maple Hills | Sink | | | Sink | 200 Wing, Shared Area, Left Sink | 200B | 17 | Install filter, retest | 3/31/2023 |
| Maple Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 203 | 203 | 11 | Install filter, retest | 3/31/2023 |
| Maple Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 201 | 201 | 14 | Install filter, retest | 3/31/2023 |
| Maple Hills | Sink health | health room | health | Sink | Health Office | 103 | 9.7 | Install filter, retest | 3/31/2023 |
| Maple Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 601, Upper Sink | 601 | 9.7 | Install filter, retest | 3/31/2023 |
| Maple Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 602, Upper Sink | 602 | 12 | Install filter, retest | 3/31/2023 |
| Maple Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 504 | 504 | 15 | Install filter, retest | 3/31/2023 |
| Maple Hills | Sink office | OT office | office | Sink | 500 Wing, Custodial | 505 | 17 | Install filter, retest | 3/31/2023 |
| Maple Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 507, Lower Sink | 507 | 16 | Install filter, retest | 3/31/2023 |
| Maple Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 507, Upper Sink | 507 | 18 | Install filter, retest | 3/31/2023 |
| Maywood | Sink classroom - regular | classroom | classroom - regular | Sink | Room 106 - sink | 106 | 6.7 | Install filter, retest | 3/31/2023 |
| Maywood | Sink classroom - regular | classroom | classroom - regular | Sink | Room 105 - sink | 105 | 8 | Install filter, retest | 3/31/2023 |
| Maywood | Sink classroom - regular | classroom | classroom - regular | Sink | Room 212 - sink | 212 | 5.6 | Install filter, retest | 3/31/2023 |
| Newcastle | Sink kitchen | kitchen | kitchen | Sink | Room 175 Kitchen - left sink | 175 | 5.52 | Install filter, retest | 3/31/2023 |
| Newcastle | Sink kitchen | kitchen | kitchen | Sink | Room 175 Kitchen Bathroom - sink | 175 | 6.35 | Install filter, retest | 3/31/2023 |
| Newcastle | Sink classroom - regular | OT/PT | classroom - regular | Sink | Room 188 OT/Support Room - bathroom sink | 188 | 9.32 | Install filter, retest | 3/31/2023 |
| Newcastle | Sink health | health room | health | Sink | Room 208 Health Room Bathroom - sink | 208 | 6.05 | Install filter, retest | 3/31/2023 |
| Newcastle | Sink | | | Sink | Custodial sink - initial draw | unknown | 19 | Install filter, retest | 3/31/2023 |
| Pacific Cascade | Sink classroom - regular | classroom | classroom - regular | Sink | Room 2109 | 2109 | 13 | Install filter, retest | 3/31/2023 |
| Sunset | Sink classroom - regular | classroom | classroom - regular | Sink | Room C22 - sink | C22 | 5.8 | Install filter, retest | 3/31/2023 |
| Sunset | Sink classroom - regular | classroom | classroom - regular | Sink | Room D28 - sink | D28 | 6.5 | Install filter, retest | 3/31/2023 |
| Sunset | Sink classroom - regular | classroom | classroom - regular | Sink | Room B11 - sink | B11 | 5.6 | Install filter, retest | 3/31/2023 |
| Sunny Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 244 | 244 | 5.2 | Install filter, retest | 3/31/2023 |
| Sunny Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 247 | 247 | 6.5 | Install filter, retest | 3/31/2023 |
| Sunny Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 248 | 248 | 8.2 | Install filter, retest | 3/31/2023 |
| Sunny Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 241 | 241 | 5.1 | Install filter, retest | 3/31/2023 |
| Sunny Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 251 | 251 | 5.3 | Install filter, retest | 3/31/2023 |
| Sunny Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 264 | 264 | 6.2 | Install filter, retest | 3/31/2023 |
| Sunny Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 267 | 267 | 6 | Install filter, retest | 3/31/2023 |
| Sunny Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 110 | 110 | 6.5 | Install filter, retest | 3/31/2023 |
| Sunny Hills | Sink classroom - regular | classroom | classroom - regular | Sink | Room 163 | 163 | 5.1 | Install filter, retest | 3/31/2023 |
| Skyline | Sink kitchen | kitchen | kitchen | Sink | Kitchen, SE Dishwashing Sinks-Left | 3061 | 15 | Install filter, retest | 3/31/2023 |
| Skyline | Sink kitchen | kitchen servery | kitchen | Sink | Servery, Handwashing Sink | 3066 | 6.6 | Install filter, retest | 3/31/2023 |
| Skyline | Sink classroom - regular | classroom | classroom - regular | Sink | Room 1214 | 1214 | 9.4 | Install filter, retest | 3/31/2023 |
| Skyline | Sink classroom - regular | classroom | classroom - regular | Sink | Room 1412, Left Sink | 1412 | 15 | Install filter, retest | 3/31/2023 |
| Skyline | Sink classroom - regular | classroom | classroom - regular | Sink | Room 1416 | 1416 | 9.7 | Install filter, retest | 3/31/2023 |
| Skyline | Sink classroom - regular | classroom | classroom - regular | Sink | Room 1418 | 1418 | 18 | Install filter, retest | 3/31/2023 |
| Skyline | Sink classroom - regular | classroom | classroom - regular | Sink | Room 1418 | 1418 | 18 | Install filter, retest | 3/31/2023 |
| Skyline | Sink classroom - regular | classroom | classroom - regular | Sink | Room 1416 | 1416 | 9.2 | Install filter, retest | 3/31/2023 |
| Skyline | Sink classroom - regular | classroom | classroom - regular | Sink | Room 2407, SE Wall | 2407 | 19 | Install filter, retest | 3/31/2023 |
| Skyline | Sink classroom - regular | classroom | classroom - regular | Sink | Room 2214 | 2214 | 13 | Install filter, retest | 3/31/2023 |
| Skyline | Sink classroom - regular | classroom | classroom - regular | Sink | Room 2212 | 2212 | 12 | Install filter, retest | 3/31/2023 |
| Skyline | Sink classroom - regular | classroom | classroom - regular | Sink | Room 2207, Computer Lab | 2207 | 19 | Install filter, retest | 3/31/2023 |
| Skyline | Sink kitchen | DECA store | kitchen | Sink | Room 2062, West Wall, Right Sink | 2062 | 5.7 | Install filter, retest | 3/31/2023 |
| Skyline | Sink | | | Sink | Stadium, Concessions, Right Handwashing Sink | stadium | 15 | Install filter, retest | 3/31/2023 |

Attachment A: Drinking Fountains and Sinks with needed remediation under new 5PPB Standard

| School | Fixture type and room type | Room Description | Type of Space | Fixture Type | Location | room # | Result (ppb) | Actions | Schedule |
|-----------------|---------------------------------------|------------------------|---------------------|-------------------|---|--------|--------------|--|------------|
| Apollo | drinking fountain classroom - regular | LRC1 classroom | classroom - regular | drinking fountain | Room 201 Classroom - drinking fountain | 201 | 5.1 | Install filter, retest | 12/31/2022 |
| Apollo | kettle kitchen | kitchen | kitchen | kettle | Kitchen - kettle | 611 | 8.1 | Install filter, retest | 12/31/2022 |
| Apollo | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 305 Classroom - drinking fountain | 305 | 5.7 | Install filter, retest | 12/31/2022 |
| Apollo | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 406 Classroom - drinking fountain | 406 | 6.4 | Install filter, retest | 12/31/2022 |
| Briarwood | kettle kitchen | kitchen | kitchen | kettle | Room 175, Kitchen, Center Island - kettle | 175 | 16 | Shut off immediately, install filter, retest | 12/31/2022 |
| Beaver Lake | kettle kitchen | kitchen | kitchen | kettle | Kitchen, Kett'e | 118 | 17 | Shut off immediately, install filter, retest | 12/31/2022 |
| Beaver Lake | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room B-3 | 83 | 5.5 | Install filter, retest | 12/31/2022 |
| Beaver Lake | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room B-2 | 82 | 10 | Install filter, retest | 12/31/2022 |
| Beaver Lake | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room D-6 | 06 | 5.4 | Install filter, retest | 12/31/2022 |
| Beaver Lake | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room D-3 | 03 | 6.3 | Install filter, retest | 12/31/2022 |
| Challenger | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 213 Classroom - drinking fountain | 213 | 7.6 | Install filter, retest | 12/31/2022 |
| Challenger | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 208 Classroom - drinking fountain | 208 | 5.8 | Install filter, retest | 12/31/2022 |
| Challenger | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 413 Classroom - drinking fountain | 413 | 8 | Install filter, retest | 12/31/2022 |
| Challenger | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 411 Classroom - drinking fountain | 411 | 6.8 | Install filter, retest | 12/31/2022 |
| Challenger | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 403 Classroom - drinking fountain | 403 | 5.7 | Install filter, retest | 12/31/2022 |
| Challenger | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 308 Classroom - drinking fountain | 308 | 6.7 | Install filter, retest | 12/31/2022 |
| Challenger | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 306 Classroom - drinking fountain | 306 | 6.9 | Install filter, retest | 12/31/2022 |
| Challenger | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 305 Classroom - drinking fountain | 305 | 5.4 | Install filter, retest | 12/31/2022 |
| Challenger | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 303 Classroom - drinking fountain | 303 | 8.7 | Install filter, retest | 12/31/2022 |
| Challenger | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 302 Classroom - drinking fountain | 302 | 6.6 | Install filter, retest | 12/31/2022 |
| Cougar Ridge | kettle kitchen | kitchen | kitchen | kettle | Room 190B, Kitchen, North Hallway - sink | 190B | 8.8 | Install filter, retest | 12/31/2022 |
| Cougar Ridge | drinking fountain classroom - regular | kindergarten classroom | classroom - regular | drinking fountain | Room 140, Classroom - right sink, drinking fountain | 140 | 5.6 | Install filter, retest | 12/31/2022 |
| Cascade Ridge | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 161 Classroom - drinking fountain | 161 | 6.1 | Install filter, retest | 12/31/2022 |
| Discovery | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 18 - drinking fountain | 180 | 10.9 | Install filter, retest | 12/31/2022 |
| Discovery | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 4 - drinking fountain | 128 | 5.22 | Install filter, retest | 12/31/2022 |
| Discovery | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 7 - left drinking fountain | 134 | 6.08 | Install filter, retest | 12/31/2022 |
| Discovery | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 7 - right drinking fountain | 134 | 5.67 | Install filter, retest | 12/31/2022 |
| Discovery | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 8 - left drinking fountain | 136 | 8.57 | Install filter, retest | 12/31/2022 |
| Discovery | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 8 - right drinking fountain | 136 | 5.46 | Install filter, retest | 12/31/2022 |
| Endeavour | kettle kitchen | kitchen | kitchen | kettle | Kitchen, Along Back Wall - kettle | 403 | 6.3 | Install filter, retest | 12/31/2022 |
| Endeavour | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 503, Classroom - drinking fountain | 503 | 5.5 | Install filter, retest | 12/31/2022 |
| Endeavour | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 507, Classroom - right sink fixture, drinking fountain | 507 | 5.4 | Install filter, retest | 12/31/2022 |
| Endeavour | drinking fountain storage | custodian storage | storage | drinking fountain | Room 204, Activity Center - left fixture, drinking fountain | 204 | 11 | Install filter, retest | 12/31/2022 |
| Endeavour | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 103, Classroom - drinking fountain | 103 | 7.9 | Install filter, retest | 12/31/2022 |
| Grand Ridge | kettle kitchen | kitchen | kitchen | kettle | Kitchen - kettle | 175 | 18 | Shut off immediately, install filter, retest | 12/31/2022 |
| Issaquah High | drinking fountain classroom - regular | deca | classroom - regular | drinking fountain | Room 1603, Classroom - drinking fountain | 1603 | 6.6 | Install filter, retest | 12/31/2022 |
| Issaquah High | drinking fountain classroom - regular | njrotc classroom | classroom - regular | drinking fountain | Room 2605, Classroom - drinking fountain | 2605 | 13 | Install filter, retest | 12/31/2022 |
| Issaquah High | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 2309 - drinking fountain | 2309 | 9.4 | Install filter, retest | 12/31/2022 |
| Issaquah High | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 2307 - drinking fountain | 2307 | 6.9 | Install filter, retest | 12/31/2022 |
| Issaquah High | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 2303 - drinking fountain | 2303 | 5.7 | Install filter, retest | 12/31/2022 |
| Issaquah High | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 3307 - drinking fountain | 3307 | 9.2 | Install filter, retest | 12/31/2022 |
| Issaquah Valley | kettle kitchen | kitchen | kitchen | kettle | Kitchen - kettle | 612 | 15 | Install filter, retest | 12/31/2022 |
| Issaquah Valley | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 304 - drinking fountain | 304 | 19 | Shut off immediately, install filter, retest | 12/31/2022 |
| Liberty High | kettle kitchen | kitchen | kitchen | kettle | Kitchen Kettle | 3203 | 5.1 | Install filter, retest | 12/31/2022 |
| Liberty High | kettle kitchen | kitchen | kitchen | kettle | Kitchen, South Kettle | 3203 | 11 | Install filter, retest | 12/31/2022 |
| Maple Hills | kettle kitchen | kitchen | kitchen | kettle | Kitchen, Kettle | 707 | 9.2 | Install filter, retest | 12/31/2022 |
| Maple Hills | drinking fountain | | | drinking fountain | 400 Wing, Shared Area, Left DF | 400B | 11 | Install filter, retest | 12/31/2022 |
| Maple Hills | drinking fountain office | office | office | drinking fountain | Room 408 | 408 | 11 | Install filter, retest | 12/31/2022 |
| Maple Hills | drinking fountain office | office | office | drinking fountain | Room 407 | 407 | 12 | Install filter, retest | 12/31/2022 |
| Maple Hills | drinking fountain hallway | hallway | hallway | drinking fountain | 300 Wing, Shared Area, Right DF | 300A | 5.2 | Install filter, retest | 12/31/2022 |
| Maple Hills | drinking fountain health | health room | health | drinking fountain | Health Office | 103 | 6.5 | Install filter, retest | 12/31/2022 |
| Maple Hills | drinking fountain office | music office | office | drinking fountain | Room 609, Music Room Office | 609 | 9.5 | Install filter, retest | 12/31/2022 |
| Maple Hills | drinking fountain classroom - regular | classroom | classroom - regular | drinking fountain | Room 507, DF | 507 | 5.3 | Install filter, retest | 12/31/2022 |
| Newcastle | drinking fountain hallway | activity area | hallway | drinking fountain | 1st Floor 160 Wing end of hallway - drinking fountain | 160 | 5.1 | Install filter, retest | 12/31/2022 |
| Newcastle | drinking fountain health | health room | health | drinking fountain | Room 208 Health Room Office - drinking fountain | 208 | 5.04 | Install filter, retest | 12/31/2022 |
| Sunny Hills | drinking fountain gym_elementary | gym | gym_elementary | drinking fountain | Gym Portable, DF | 405 | 6.2 | Install filter, retest | 12/31/2022 |
| Sunny Hills | drinking fountain office | office | office | drinking fountain | Gym Portable, Room 406 | 406 | 19 | Shut off immediately, install filter, retest | 12/31/2022 |